



TARLAC CITY WATER DISTRICT  
WATER LABORATORY  
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1

TCWDWL/QF-BRES/-17-10-0000084

TCWDWL/QF-BRS/-17-10- 002

TCWDWL/QF-BRQ/-17- 10-0000083

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/Client:

LICAB WATER DISTRICT

Date Reported: 10/07/2017

Address:

DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Time Reported: 10:30:15 AM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B17-2521/ Sampling Pt. TAP/ Address WENILYN RAMOS/ STA MARIA	100 cc/ Clear/In Sterilized Bottle	10/4/17	10:00 am	1:16 pm	3:00 pm	<1.1	<1.1	<30
Sample Lab No. B17-2523/ Sampling Pt. TAP/ Address ELISEO SARMIENTO/ POBLACION NORTE	100 cc/ Clear/In Sterilized Bottle	10/4/17	10:45 am	1:16 pm	3:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARKS:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 22nd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

KRIS VINCENT A. SIBUG  
Medical Technologist  
PRC License No.: 48906

Electronic Copy

This document is valid without signature

The information contained in this document is privileged,  
confidential and is intended solely for the use of the individual  
or entity to whom it is addressed.

Certified correct by:

LAIZA DIANNE M. DE LEON  
Head of Laboratory  
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

Not Valid Without Dry Seal

Revision 1, Effective: 4 September 2017

Original Issue 10 May 2016

PrimeWater Tarlac City

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-0907; 982-1150

Pages 1 of 2



TARLAC CITY WATER DISTRICT  
WATER LABORATORY  
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1

TCWDWL/QF-BRES-17-10-0000138

TCWDWL/QF-BRS-17-10-007

TCWDWL/QF-BRQ-17-10-0000132

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/Client: LICAB WATER DISTRICT

Date Reported: 10/23/2017

Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Time Reported: 2:18:20 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B17-2707/ Sampling Pt. TAP/ Address CHARITO DE GUZMAN/ BRGY AQUINO LICAB	100 cc/ Clear/ In Sterilized Bottle	10/18/17	9:00 am	11:41 am	2:00 pm	<1.1	<1.1	315
Sample Lab No. B17-2708/ Sampling Pt. TAP/ Address NERI ESPERANZA/ SAN CRISTOBAL	100 cc/ Clear/ In Sterilized Bottle	10/18/17	9:55 am	11:41 am	2:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARK/S:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 22nd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

KRIS VINCENT A. SIBUG  
Medical Technologist  
PRC License No.: 48906

Certified correct by:

LAIZA DIANNE M. DE LEON  
Head of Laboratory  
PRC License No.: 51612

Electronic Copy

This document is valid without signature

The information contained in this document is privileged,  
confidential and is intended solely for the use of the individual  
or individuals named in the document.

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

Not Valid Without Dry Seal

Revision 1, Effective: 4 September 2017

Original Issue 10 May 2016

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-0907; 982-1150

Pages 1 of 1