



**TARLAC CITY WATER DISTRICT
WATER LABORATORY**
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1

TCWDWL/QF-BRES-18-01-000014
TCWDWL/QF-BRS-18-01-001
TCWDWL/QF-BRO-18-01-000007

Requesting Agency/Client

BACTERIOLOGICAL WATER ANALYSIS
LICAB WATER DISTRICT

Date Reported: 01/10/2018

Address:

DON DALMACIO AVE POB SUR LICAB NUEVA ECJA

Time Reported: 11:22:48 AM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-0029/ Sampling Pt. TAP/ Address NERI ESPERANZA/ SAN CRISTOBAL	100 cc/ Clear/ In Sterilized Bottle	1/3/18	11:00 am	4:38 pm	4:45 pm	<1.1	<1.1	<30
Sample Lab No. B18-0030/ Sampling Pt. TAP/ Address ALBERTO MANUEL/ VILLAROSA	100 cc/ Clear/ In Sterilized Bottle	1/3/18	11:18 am	4:38 pm	4:45 pm	<1.1	<1.1	<30
Sample Lab No. B18-0031/ Sampling Pt. TAP/ Address ANSELMA CARRIDO/ P3 STA MARIA	100 cc/ Clear/ In Sterilized Bottle	1/3/18	11:10 am	4:38 pm	4:45 pm	<1.1	<1.1	58
Sample Lab No. B18-0032/ Sampling Pt. TAP/ Address ROMINICK GARCIA/ P5 STA MARIA	100 cc/ Clear/ In Sterilized Bottle	1/3/18	11:25 am	4:38 pm	4:45 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARKS:

Result of examination specifically relates to samples as received.
The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

- Standard method for the examination of Water and Wastewater, 23rd Edition
- Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010
- For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

KRIS VINCENT A. SIBUG
Medical Technologist
PRC License No.: 48906



Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

Not Valid Without Dry Seal
Revision 1, Effective: 4 September 2017
Original Issue 10 May 2016

TCWDWL/QF-BRES

PrimeWater Tarlac City

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-0907; 982-1150