



**TARLAC CITY WATER DISTRICT  
WATER LABORATORY**

UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1

TCWDWL/QF-BRES-18-02-0000148

TCWDWL/QF-BRS-18-02-001

TCWDWL/QF-BRQ-18-02-0000138

**BACTERIOLOGICAL WATER ANALYSIS**

Requesting Agency/Client:

LICAB WATER DISTRICT

Date Reported: 02/14/2018

Address:

DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Time Reported: 2:17:40 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-0465/ Sampling Pt. TAP/ Address FELINA SIBLAG/ P5 STA MARIA	100 cc/ Clear/ In Sterilized Bottle	2/7/18	8:55 am	12:19 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-0466/ Sampling Pt. TAP/ Address LILIBETH ENRIQUEZ/ P6 STA MARIA	100 cc/ Clear/ In Sterilized Bottle	2/7/18	8:45 am	12:19 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-0467/ Sampling Pt. TAP/ Address LORELIE SANGIL/ SAN CASIMIRO	100 cc/ Clear/ In Sterilized Bottle	2/7/18	8:50 am	12:19 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-0468/ Sampling Pt. TAP/ Address BERNARD VELASQUEZ/ POB NORTE	100 cc/ Clear/ In Sterilized Bottle	2/7/18	9:15 am	12:19 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-0469/ Sampling Pt. TAP/ Address EMLITA DEL ROSARIO/ POB SUR	100 cc/ Clear/ In Sterilized Bottle	2/7/18	9:30 am	12:19 pm	1:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARKS:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

**KRIS VINCENT A. SIBUG**  
Medical Technologist  
PRC License No.: 48908

Certified correct by:

**LAIZA DIANNE M. DE LEON**  
Head of Laboratory  
PRC License No.: 51612

**Electronic Copy**

This document is valid without signature  
Date: 02/14/2018 2:17:40 PM  
IP: 192.168.1.100

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

Not Valid Without Dry Seal