



TARLAC CITY WATER DISTRICT
WATER LABORATORY
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1

TCWDWL/QF-BRES/-18-03-0000206
TCWDWL/QF-BRS/-18-02-009
TCWDWL/QF-BRO/-18-02-0000194

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/Client: LICAB WATER DISTRICT
Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Date Reported: 03/06/2018
Time Reported: 11:52:33 AM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-0664/ Sampling Pt. TAP/ Address POB. SUR PUMPING STATION/POB. SUR, LICAB	100 cc/ Clear/ In Sterilized Bottle	2/27/18	11:00 am	2:04 pm	3:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:
SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli
SMEWW 9215B Pour Plate Method for the determination of HPC

REMARK/S:
Result of examination specifically relates to samples as received.
The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:
Standard method for the examination of Water and Wastewater, 23rd Edition
Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010
For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

KRIS VINCENT A. SIBUG
Medical Technologist
PRC License No.: 48906

Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL
TCWDWL/QF-BRES

Not Valid Without Dry Seal
Revision 1, Effective: 4 September 2017
Original Issue 10 May 2016



TARLAC CITY WATER DISTRICT
WATER LABORATORY
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1

BACTERIOLOGICAL WATER ANALYSIS

TCWDWL/QF-BRES/-18-03-0000224
TCWDWL/QF-BRS/-18-03- 002
TCWDWL/QF-BRQ/-18- 03-0000210

Requesting Agency/Client: LICAB WATER DISTRICT

Date Reported: 03/12/2018

Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Time Reported: 3:31:09 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-0726 Sampling Pt. TAP Address ROMEO GATMAITAN/ SAN CRISTOBAL	100 cc/ Clear In Sterilized Bottle	03/06/18	10:25 AM	12:43 PM	1:00 PM	<1.1	<1.1	<30
Sample Lab No. B18-0727 Sampling Pt. TAP Address GEORGE BUMANLAG/ POB NORTE	100 cc/ Clear In Sterilized Bottle	03/06/18	10:45 AM	12:43 PM	1:00 PM	<1.1	<1.1	<30
Sample Lab No. B18-0728 Sampling Pt. TAP Address POB SUR PUMPING STATION/ POB SUR	100 cc/ Clear In Sterilized Bottle	03/06/18	9:05 AM	12:43 PM	1:00 PM	<1.1	<1.1	<30
Sample Lab No. B18-0729 Sampling Pt. TAP Address ANSEMA GARRIDO/ P6 STA MARIA	100 cc/ Clear In Sterilized Bottle	03/06/18	10:45 AM	12:43 PM	1:00 PM	<1.1	<1.1	<30
Sample Lab No. B18-0730 Sampling Pt. TAP Address IRENEO FERMIN/ P6 STA MARIA	100 cc/ Clear In Sterilized Bottle	03/06/18	9:50 AM	12:43 PM	1:00 PM	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARKS:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO. NO. 2017-0010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 22nd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

KRIS VINCENT A. SIBUG
Medical Technologist
PRC License No.: 48906

Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

Not Valid Without Dry Seal

Revision 1, Effective: 4 September 2017

Original Issue 10 May 2016

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-0907; 982-1150

PrimeWater Tarlac City

Pages 1 of 1