



**TARLAC CITY WATER DISTRICT  
WATER LABORATORY**  
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



**ACCREDITATION NUMBER: 03-0003-16-LW-1**

TCWDWL/QF-BRES/-18-04-0000325

TCWDWL/QF-BRS/-18-04-004

TCWDWL/QF-BRO/-18-04-0000311

**BACTERIOLOGICAL WATER ANALYSIS**

**Requesting Agency/Client:**

**LICAB WATER DISTRICT**

Date Reported: 04/18/2018

**Address:**

**DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA**

Time Reported: 11:22:08 AM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-1112/ Sampling Pt. TAP/ Address POB. SUR, LICAB, NE	200 cc/ Clear/ In Sterilized Bottle	4/11/18	9:27 am	11:07 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-1113/ Sampling Pt. TAP/ Address STA. MARIA, LICAB, NE	200 cc/ Clear/ In Sterilized Bottle	4/11/18	9:42 am	11:07 am	1:00 pm	<1.1	<1.1	<30
<b>Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard</b>						<1.1	<1.1	<500

**TEST METHOD USED:**

**SMEWW 9221 Multiple Tube Fermentation Technique with HPC**, for the determination of total and thermotolerant coliforms/E. Coli

**SMEWW 9215B Pour Plate Method** for the determination of HPC

**REMARKS:**

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

**REFERENCES:**

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

**KRIS VINCENT A. SIBUG**  
Medical Technologist  
PRC License No.: 48906



Certified correct by:

**LAIZA DIANNE M. DE LEON**  
Head of Laboratory  
PRC License No.: 51612

*This report shall not be reproduced, except in full without the written approval of TCWDWL*

Not Valid Without Dry Seal

TCWDWL/QF-BRES

Revision 1, Effective: 4 September 2017

PrimeWater Tarlac City

Original Issue 10 May 2016

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-0907; 982-1150

Pages 1 of 1