



**TARLAC CITY WATER DISTRICT
WATER LABORATORY**
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE

ACCREDITATION NUMBER: 03-0003-16-LW-1

**BACTERIOLOGICAL WATER ANALYSIS
LICAB WATER DISTRICT**

Requesting Agency/Client:

Address:

DON DALMACIO AVE POB SUR LICAB NUEVA ECUIJA

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time			
		Date	Collection	Receipt	Exam
Sample Lab No. B18-1689/ Sampling Pt. TAP/ Address NDIRMA PADOLINA/ P6 STA MARIA LICAB NE	100 cc/ Clear/ In Sterilized Bottle	6/5/18	7:40 am	10:27 am	3
Sample Lab No. B18-1690/ Sampling Pt. TAP/ Address SALOME PALLARCO/ P2 STA MARIA LICAB NE	100 cc/ Clear/ In Sterilized Bottle	6/5/18	7:55 am	10:27 am	3
Sample Lab No. B18-1691/ Sampling Pt. TAP/ Address GERONIMO MIGUEL/ SAN CRISTOBAL LICAB NE	100 cc/ Clear/ In Sterilized Bottle	6/5/18	8:00 am	10:27 am	3
Sample Lab No. B18-1692/ Sampling Pt. TAP/ Address JOVENICIO LACAMENTO/ POB SUR LICAB NE	100 cc/ Clear/ In Sterilized Bottle	6/5/18	8:25 am	10:27 am	3
Sample Lab No. B18-1693/ Sampling Pt. TAP/ Address HERMINIO LAMPA/ SAN JUAN LICAB NE	100 cc/ Clear/ In Sterilized Bottle	6/5/18	8:40 am	10:27 am	3
Philippine National Standards for Drinking Water 2017 and AQ 2017-0010 Standard					

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215R Pour Plate Method for the determination of HPC

REMARK/S:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition


Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

Certif

KRIS VINCENT A. SIBUG
Medical Technologist
PRC License No.: 48906



This report shall not be reproduced, except in full without the written approval of

Not Valid Without Dry Seal

TCWDWL/QF-BRES

Revision 1, Effective: 4 September 2017

Prime

Original Issue 10 May 2016

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-090

RE CORP.



TCWDWL/OF-BRES-18-06-0000476

TCWDWL/OF-BRS-18-06-002

TCWDWL/OF-BRO-18-06-0000464

Date Reported: 06/11/2018

Time Reported: 8:55:08 AM

Results of Analysis

Time	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/E. Coli (MPN/100 ml)	HPC (CFU/ml)
3:00 pm	<1.1	<1.1	<30
3:00 pm	<1.1	<1.1	<30
3:00 pm	<1.1	<1.1	<30
3:00 pm	<1.1	<1.1	<30
3:00 pm	<1.1	<1.1	<30
	<1.1	<1.1	<500

filed correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

of TCWDWL

Water Tarlac City

7; 982-1150

Pages 1 of 1

