



**TARLAC CITY WATER DISTRICT
WATER LABORATORY**
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1

TCWDWL/QF-BRES/-18-07-0000570

TCWDWL/QF-BRS/-18-07-004

TCWDWL/QF-BRO/-18-07-0000557

BACTERIOLOGICAL WATER ANALYSIS

LICAB WATER DISTRICT

Date Reported: 07/18/2018

Requesting Agency/Client:

Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Time Reported: 10:14:45 AM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-2080/ Sampling Pt. TAP/ Address LILIBETH ENRIQUEZ/ P 6 STA MARIA LICAB NE	100cc/Clear/In Sterilized Bottle	7/11/18	8:30 am	10:57 am	11:00 am	<1.1	<1.1	<30
Sample Lab No. B18-2081/ Sampling Pt. TAP/ Address BENJAMIN AGUSTIN / P 4 STA MARIA , LICAB NE	100cc/Clear/In Sterilized Bottle	7/11/18	8:50 am	10:57 am	11:00 am	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC , for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARK/S:

Result of examination specifically relates to samples as received.
The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

- Standard method for the examination of Water and Wastewater, 23rd Edition
- Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010
- For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON
Medical Technologist
PRC License No.: 0081806

Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

Electronic Copy

This document is valid without signature

The information contained in this document is privileged, confidential and is intended solely for the use of the individual or entity to which it is addressed.

This report shall not be reproduced, except in full without the written approval of TCWDWL