



# TARLAC CITY WATER DISTRICT WATER LABORATORY

UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



**ACCREDITATION NUMBER: 03-0003-16-LW-1**

*TCWDWL/QF-BRES/-18-08-0000640*

*TCWDWL/QF-BRS/-18-08-003*

*TCWDWL/QF-BRO/-18-08-0000628*

## BACTERIOLOGICAL WATER ANALYSIS

**Requesting Agency/Client:** LICAB WATER DISTRICT

Date Reported: 08/13/2018

**Address:** DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Time Reported: 4:21:10 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-2318/ Sampling Pt. TAP/ Address MYRLA BUMANLAG II / POB SUR, LICAB NE	100cc/Clear/In Sterilized Bottle	8/6/18	11:35 am	2:30 pm	3:00 pm	<1.1	<1.1	100
Sample Lab No. B18-2321/ Sampling Pt. TAP/ Address SALOME PALLIARCO / P-2 , STA MARIA, LICAB , NE	100cc/Clear/In Sterilized Bottle	8/6/18	12:20 pm	2:30 pm	3:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2322/ Sampling Pt. TAP/ Address ANCELMA GARRIDO / P-3, STA MARIA, LICAB, NE	100cc/Clear/In Sterilized Bottle	8/6/18	12:30 pm	2:30 pm	3:00 pm	<1.1	<1.1	99
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

**TEST METHOD USED:**

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

**REMARKS:**

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

**REFERENCES:**

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

**Analysis conducted by:**

**DENISSA ANNE G. AYSON**  
Medical Technologist  
PRC License No.: 0081806

**Certified correct by:**

**LAIZA DIANNE M. DE LEON**  
Head of Laboratory  
PRC License No.: 51612

*This report shall not be reproduced, except in full without the written approval of TCWDWL*

TCWDWL/QF-BRES

**Not Valid Without Dry Seal**

Revision 1, Effective: 4 September 2017

Original Issue 10 May 2016

PrimeWater Tarlac City

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-0907; 982-1150

Pages 1 of 2