

Address:

TARLAC CITY WATER DISTRICT WATER LABORATORY

UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1

TCWDWL/OF-BRES/-18-09-0000705 TCWDWL/QF-BRS/-18- 09-001 TCWDWL/QF-BRQ/-18-09-0000693

BACTERIOLOGICAL WATER ANALYSIS

DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Time Reported:

Date Reported:

1:19:22 PM

09/10/2018

Requesting Agency/Client: LICAB WATER DISTRICT

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-2568/ Sampling Pt. TAP/ Address LORELIE SANGIL/SAN CASIMIRO, LICAB N.E.	300cc/Clear/In Sterilized Bottle	9/3/18	11:25 am	2:23 pm	3:10 pm	<1.1	<1.1	<30
Sample Lab No. B18-2569/ Sampling Pt. TAP/ Address JOVENCIO LACAMENTO/ POB. SUR, LICAB N.E.	300cc/Clear/In Sterilized Bottle	9/3/18	11:41 am	2:23 pm	3:10 pm	<1.1	<1.1	<30
Sample Lab No. B18-2570/ Sampling Pt. TAP/ Address NERI ESPERANZA/SAN CRISTOBAL, LICAB N.E.	300cc/Clear/In Sterilized Bottle	9/3/18	11:58 am	2:23 pm	3:10 pm	<1.1	<1.1	<30
Sample Lab No. B18-2571/ Sampling Pt. TAP/ Address CEVERINO JACINTO / P-5 STA. MARIA, LICAB N.E.	300cc/Clear/In Sterilized Bottle	9/3/18	12:00 pm	2:23 pm	3:10 pm	<1.1	<1.1	58
Sample Lab No. B18-2572/ Sampling Pt. TAP/ Address MELANIE MANALANG/P-6 STA. MARIA, LICAB, N.E.	300cc/Clear/In Sterilized Bottle	9/3/18	12:29 pm	2:23 pm	3:10 pm	<1.1	<1.1	460
		The second of		The second	San and	and the same		
	基	N Bank T	10	A Sand	None of Street			
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARK/S:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON Medical Technologist PRC License No.: 0081806

Certified correct by:

LAIZA DIANNE M. DE LEON

Head of Laboratory

PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

Not Valid Without Dry Seal Revision 1, Effective: 4 September 2017

Original Issue 10 May 2016

TCWDWL/QF-BRES

PrimeWater Tarlac City

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-0907; 982-1150

Pages 1 of 1