



**TARLAC CITY WATER DISTRICT
WATER LABORATORY**
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1

TCWDWL/QF-BRES/-18-10-0000805

TCWDWL/QF-BRS/-18- 10-002

TCWDWL/QF-BRQ/-18-10-0000792

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/Client: LICAB WATER DISTRICT

Date Reported: 10/10/2018

Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Time Reported: 2:11:49 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-2904/ Sampling Pt. TAP/ Address ALBERTO MANUEL / VILLAROSA, LICAB, NE	100cc/Clear/In Sterilized Bottle	10/3/18	9:25 am	12:32 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2905/ Sampling Pt. TAP/ Address NERI ESPERANZA / SAN CRISTOBAL, LICAB, NE	100cc/Clear/In Sterilized Bottle	10/3/18	9:00 am	12:32 pm	1:00 pm	<1.1	<1.1	37
Sample Lab No. B18-2907/ Sampling Pt. TAP/ Address GLORY LOZALDO / P-5 STA MARIA, LICAB, NE	100cc/Clear/In Sterilized Bottle	10/3/18	10:00 am	12:32 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2908/ Sampling Pt. TAP/ Address AMOR YANGO / P-1 STA MARIA, LICAB, NE	100cc/Clear/In Sterilized Bottle	10/3/18	9:40 am	12:32 pm	1:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARKS:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON
Medical Technologist
PRC License No.: 0081808

Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

Not Valid Without Dry Seal

Revision 1, Effective: 4 September 2017

Original Issue 10 May 2016

PrimeWater Tarlac City

Page 5 of 2

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-0907; 982-1150