



**TARLAC CITY WATER DISTRICT
WATER LABORATORY**
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-004-19-LW-1

TCWDWL/QF-BRES-19-02-0000115

TCWDWL/QF-BRS-19-02-002

TCWDWL/QF-BRO-19-02-0000111

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/Client: LICAB WATER DISTRICT

Date Reported: 02/13/2019

Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Time Reported: 9:47:30 AM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B19-0404/ Sampling Pt. TAP/ Address LORELIE SANGIL / SAN CASIMIRO, LICAB NE	100cc/Clear/In Sterilized Bottle	2/6/19	9:20 am	1:13 pm	2:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0405/ Sampling Pt. TAP/ Address LOLITA DELA CRUZ / SAN CRISTOBAL, LICAB NE	100cc/Clear/In Sterilized Bottle	2/6/19	9:45 am	1:13 pm	2:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0406/ Sampling Pt. TAP/ Address ELISA ABRENICA / SAN JUAN, LICAB NE	100cc/Clear/In Sterilized Bottle	2/6/19	10:05 am	1:13 pm	2:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0407/ Sampling Pt. TAP/ Address SALOME PALLARCO / P2-STA MARIA, LICAB NE	100cc/Clear/In Sterilized Bottle	2/6/19	9:55 am	1:13 pm	2:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0408/ Sampling Pt. TAP/ Address ANCELMA GARIDO / P-3 STA MARIA, LICAB NE	100cc/Clear/In Sterilized Bottle	2/6/19	10:05 am	1:13 pm	2:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0409/ Sampling Pt. TAP/ Address CELSO BUMANLAG / POB SUR, LICAB NE	100cc/Clear/In Sterilized Bottle	2/6/19	10:30 am	1:13 pm	2:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARK/S:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON

Medical Technologist

PRC License No.: 0081806

Certified correct by:

LAIZA DIANNE M. DE LEON

Head of Laboratory

PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

Not Valid Without Dry Seal

Revision 1, Effective: 4 September 2017

Original Issue 10 May 2016

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-0907; 982-1150

PrimeWater Tarlac City

Pages 1 of 1