TARLAC CITY WATER DISTRICT
WATER LABORATORY

UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.

ACCREDITATION NUMBER: 03-004-19-LW-1

TCWDWL/QF-BRES/-19-04-0000280a
TCWDWL/QF-BRS/-19- 04-002
TCWDWL/QF-BRQ/-19-04-0000277

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/Client: **LICAB WATER DISTRICT**

Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Date Reported: 04/10/2019

Time Reported: 3:24:43 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B19-1021/ Sampling Pt. TAP/ Address NERI ESPARANZA / SAN CRISTOBAL, LICAB, NE	100cc/Clear/In Sterilized Bottle	4/3/19	9:00 am	1:08 pm	2:00 pm	<1.1	<1.1	240
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARK/S:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON
Medical Technologist
PRC License No.: 0081806

Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TARLAC CITY WATER DISTRICT
WATER LABORATORY

UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.

ACCREDITATION NUMBER: 03-004-19-LW-1

TCWDWL/QF-BRES/-19-04-0000280b
TCWDWL/QF-BRS/-19- 04-002
TCWDWL/QF-BRQ/-19-04-0000277

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/Client: LICAB WATER DISTRICT

Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Date Reported: 04/10/2019

Time Reported: 3:24:43 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B19-1022/ Sampling Pt. TAP/ Address ELISEO SARMIENTO / POB NORTE, LICAB, NE	100cc/Clear/In Sterilized Bottle	4/3/19	9:20 am	1:08 pm	2:00 pm	<1.1	<1.1	39
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARK/S:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON
Medical Technologist
PRC License No.: 0081806

Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TARLAC CITY WATER DISTRICT
WATER LABORATORY

UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.

ACCREDITATION NUMBER: 03-004-19-LW-1

TCWDWL/QF-BRES/-19-04-0000280d
TCWDWL/QF-BRS/-19-04-002
TCWDWL/QF-BRQ/-19-04-0000277

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/Client: **LICAB WATER DISTRICT**

Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Date Reported: 04/10/2019

Time Reported: 3:24:43 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B19-1024/ Sampling Pt. TAP/ Address JOVENCIO LACAMENTO / POB SUR, LICAB, NE	100cc/Clear/In Sterilized Bottle	4/3/19	9:50 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARK/S:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON
Medical Technologist
PRC License No.: 0081806

Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TARLAC CITY WATER DISTRICT
WATER LABORATORY

UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.

ACCREDITATION NUMBER: 03-004-19-LW-1

TCWDWL/QF-BRES/-19-04-0000280e
TCWDWL/QF-BRS/-19- 04-002
TCWDWL/QF-BRQ/-19-04-0000277

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/Client: **LICAB WATER DISTRICT**

Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Date Reported: 04/10/2019

Time Reported: 3:24:43 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B19-1025/ Sampling Pt. TAP/ Address AMOR YANGO / P-3 STA MARIA, LICAB, NE	100cc/Clear/In Sterilized Bottle	4/3/19	9:45 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARK/S:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON
Medical Technologist
PRC License No.: 0081806

Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TARLAC CITY WATER DISTRICT
WATER LABORATORY

UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.

ACCREDITATION NUMBER: 03-004-19-LW-1

TCWDWL/QF-BRES -19-04-0000280f
TCWDWL/QF-BRS/-19- 04-002
TCWDWL/QF-BRQ/-19-04-0000277

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/Client: **LICAB WATER DISTRICT**

Address: DON DALMACIO AVE POB SUR LICAB NUEVA ECIJA

Date Reported: 04/10/2019

Time Reported: 3:24:43 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B19-1026/ Sampling Pt. TAP/ Address BENJAMIN AGUSTIN / P-4 STA MARIA, LICAB, NE	100cc/Clear/In Sterilized Bottle	4/3/19	10:00 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARK/S:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON
Medical Technologist
PRC License No.: 0081806

Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL