

CABANATUAN CITY WATER DISTRICT WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telefax (44) 463-2877, 463-1646 to 47, 940-1216
DOH Accreditation #03-001-18-LW-1

WATER MICROBIOLOGY ANALYSIS REPORT

Client: **LICAB WATER DISTRICT**
Owner/Manager: **ANNE LORELIE DL. LAURETA**
Address: **DON PALMACIO AVE., POB. SUR, LICAB,
NUEVA ECIJA**

WMAR No: **19-707**
Date Received: **October 01, 2019**
Date Analyzed: **October 01, 2019**
Date Completed: **October 03, 2019**


Physical Characteristics: **Sample is clear, with no foreign matter**


Concessionaire	Location	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Jimmy Balais	P-6 San Cristobal	October 01, 2019 10:00 AM	2	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note:
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received



Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiñaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

CCWDLAB-FORM02-00

Page 1 of 1

NOT VALID WITHOUT DRY SEAL



CABANATUAN CITY WATER DISTRICT WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telefax (44) 463-2877, 463-1646 to 47, 940-1216
DOH Accreditation #03-001-18-LW-1

WATER MICROBIOLOGY ANALYSIS REPORT

Client: **LICAB WATER DISTRICT**
Owner/Manager: **ANNE LORELIE DL. LAURETA**
Address: **DON PALMACIO AVE., POB. SUR, LICAB,
NUEVA ECIJA**

WMAR No: **19-707B**
Date Received: **October 01, 2019**
Date Analyzed: **October 01, 2019**
Date Completed: **October 03, 2019**


Physical Characteristics: **Sample is clear, with no foreign matter**


Concessionaire	Location	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
April Tumacder	P-3 Villarosa	October 01, 2019 10:16 AM	310	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note:
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received



Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiñait, MD, FPSP
Head of the Laboratory, PRC No. 64242

CCWDLAB-FORM02-00

Page 1 of 1

NOT VALID WITHOUT DRY SEAL



CABANATUAN CITY WATER DISTRICT WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telefax (44) 463-2877, 463-1646 to 47, 940-1216
DOH Accreditation #03-001-18-LW-1

WATER MICROBIOLOGY ANALYSIS REPORT

Client: **LICAB WATER DISTRICT**
Owner/Manager: **ANNE LORELIE DL. LAURETA**
Address: **DON PALMACIO AVE., POB. SUR, LICAB,
NUEVA ECIJA**

WMAR No: **19-707C**
Date Received: **October 01, 2019**
Date Analyzed: **October 01, 2019**
Date Completed: **October 03, 2019**


Physical Characteristics: **Sample is clear, with no foreign matter**

Concessionaire	Location	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Jovencio Lacamento	Pob. Sur	October 01, 2019 10:00 AM	9	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter


MPN/100mL = Most Probable Number per 100 milliliters

- Note:
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

CCWDLAB-FORM02-00
Page 1 of 1


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242



CABANATUAN CITY WATER DISTRICT WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telefax (44) 463-2877, 463-1646 to 47, 940-1216
DOH Accreditation #03-001-18-LW-1

WATER MICROBIOLOGY ANALYSIS REPORT

Client: **LICAB WATER DISTRICT**
Owner/Manager: **ANNE LORELIE DL. LAURETA**
Address: **DON PALMACIO AVE., POB. SUR, LICAB,
NUEVA ECIJA**

WMAR No: **19-707D**
Date Received: **October 01, 2019**
Date Analyzed: **October 01, 2019**
Date Completed: **October 03, 2019**

Physical Characteristics: **Sample is clear, with no foreign matter**

Concessionaire	Location	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Patricia Lampa	San Juan	October 01, 2019 10:35 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note:
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

CCWDLAB-FORM02-00

Page 1 of 1

NOT VALID WITHOUT DRY SEAL

WATER MICROBIOLOGY ANALYSIS REPORT

Client: **LICAB WATER DISTRICT**
Owner/Manager: **ANNE LORELIE DL. LAURETA**
Address: **DON PALMACIO AVE., POB. SUR, LICAB,
NUEVA ECIJA**

WMAR No: **19-707E**
Date Received: **October 01, 2019**
Date Analyzed: **October 01, 2019**
Date Completed: **October 03, 2019**


Physical Characteristics: **Sample is clear, with no foreign matter**


Concessionaire	Location	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Amor Yango	P-3 Sta. Maria	October 01, 2019 10:35 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters


- Note:
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiñait, MD, FPSP
Head of the Laboratory, PRC No. 64242

CCWDLAB-FORM02-00

Page 1 of 1



CABANATUAN CITY WATER DISTRICT WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telefax (44) 463-2877, 463-1646 to 47, 940-1216
DOH Accreditation #03-001-18-LW-1

WATER MICROBIOLOGY ANALYSIS REPORT

Client: **LICAB WATER DISTRICT**
Owner/Manager: **ANNE LORELIE DL. LAURETA**
Address: **DON PALMACIO AVE., POB. SUR, LICAB,
NUEVA ECIJA**

WMAR No: **19-707F**
Date Received: **October 01, 2019**
Date Analyzed: **October 01, 2019**
Date Completed: **October 03, 2019**


Physical Characteristics: **Sample is clear, with no foreign matter**


Concessionaire	Location	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Salome Palliarco	P-2 Sta. Maria	October 01, 2019 10:45 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note:
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

CCWDLAB-FORM02-00

Page 1 of 1

NOT VALID WITHOUT DRY SEAL