

229 Maharlika Road, Dicarma District. Cabanatuan City, Philippines

DOH Accreditation #03-001-18-LW-1

Telephone: (044) 463-1646 / 47 local 505

@ ccwdwaterlab@gmail.com

### WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0203F

Owner/Manager:

ANNE LORELIE DL. LAURETA

03/02/2020

Address

DON PALMACIO AVE., POB SUR, LICAB, **NUEVA ECIJA** 

Date Analyzed:

Date Received:

03/02/2020

Date Completed:

03/04/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampling		(MPN/100mL)		М.
April Tumacder	P-3 Villarosa	March 02, 2020 11:00 AM	4	<1.1	<1.1	PASSED
#	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Analyst, PAM No. 18-00303

CCWDLAB-FORM02-01

Page 6 of 6

Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

NOT VALID WITHOUT DRY SEAL



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

DOH Accreditation #03-001-18-LW-1

(C) Telephone: (044) 463-1646 / 47 local 505

@ ccwdwaterlab@gmail.com

### WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0203E

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

03/02/2020

Address

DON PALMACIO AVE., POB SUR, LICAB,

Date Analyzed:

03/02/2020

**NUEVA ECIJA** 

Date Completed:

03/04/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
				(MPN/100mL)		ч.
Neri Esperanza	San Cristobal	March 02, 2020 10:44 AM	3	<1.1	<1.1	PASSED
н	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF

3. Result of examination specifically relates to samples as received

Analyst, PAM No. 18-00303

CCWDLAB-FORM02-01 Page 5 of 6

NOT VALID WITHOUT DRY SEAL

Quiaoit, MD, FPSP



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-001-18-LW-1

Telephone: (044) 463-1646 / 47 local 505

@ ccwdwaterlab@gmail.com

#### WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0203D

Owner/Manager:

ANNE LORELIE DL. LAURETA

03/02/2020

Address

DON PALMACIO AVE., POB SUR, LICAB,

00/02/202

**NUEVA ECIJA** 

Date Analyzed :

Date Received:

03/02/2020

Date Completed:

03/04/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
				(MPN/100mL)		N.
Emilie Aquino	Pob. Norte	March 02, 2020 11:28 AM	1	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMicro

Analyst, PAM No. 18-00303

CCWDLAB-FORM02-01 Page 4 of 6

**NOT VALID WITHOUT DRY SEAL** 

Susana P. Quiaoit, MD, FPSP



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 463-1646 / 47 local 505

DOH Accreditation #03-001-18-LW-1

@ ccwdwaterlab@gmail.com

### WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0203C

Owner/Manager:

ANNE LORELIE DL. LAURETA

03/02/2020

Address

DON PALMACIO AVE., POB SUR, LICAB.

Date Received : Date Analyzed :

03/02/2020

**NUEVA ECIJA** 

Date Completed :

03/04/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampling		(MPN/100mL)		4.
Elisa Abrenica	San Juan	March 02, 2020 11:15 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Veronica A. Presentación, RMicro Analyst, PAM No. 18-00303

CCWDLAB-FORM02-01 Page 3 of 6

NOT VALID WITHOUT DRY SEAL

Susana P. Quiaoit, MD, FPSP



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-001-18-LW-1

Telephone: (044) 463-1646 / 47 local 505

@ ccwdwaterlab@gmail.com

### WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0203B

Owner/Manager:

ANNE LORELIE DL. LAURETA

03/02/2020

Address

DON PALMACIO AVE., POB SUR, LICAB,

03/02/2020

NUEVA ECIJA

Date Analyzed : Date Completed :

Date Received:

03/04/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
				(MPN/100mL)		Man
Reyglan Apellido	P-5 Sta. Maria	March 02, 2020 10:55 AM	3	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMicro Analyst, PAM No. 18-00303

CCWDLAB-FORM02-01

Page 2 of 6

NOT VALID WITHOUT DRY SEAL

Susana P. Quiaoit, MD, FPSP



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

•

DOH Accreditation #03-001-18-LW-1

Telephone: (044) 463-1646 / 47 local 505

#03-001-18-LW-1

@ ccwdwaterlab@gmail.com

#### WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0203A

Owner/Manager:

ANNE LORELIE DL. LAURETA

03/02/2020

Address

DON PALMACIO AVE., POB SUR, LICAB,

Date Received : Date Analyzed :

03/02/2020

**NUEVA ECIJA** 

Date Completed :

03/04/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
	e e	Sampling	(Est. CFU/mL)			ж.
Salome Pallarco	P-2 Sta. Maria	March 02, 2020 10:40 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMicro Analyst, PAM No. 18-00303

CCWDLAB-FORM02-01 Page 1 of 6

NOT VALID WITHOUT DRY SEAL

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242