

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0323F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	06/03/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIIJA	Date Analyzed :	06/03/2020
		Date Completed :	06/05/2020


Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform		Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)			
Amor Yango	P-3 Sta. Maria	June 03, 2020 08:15 AM	1	<1.1	<1.1		PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1		


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
1. Test method used:
 - a. Pour Plate Method for the determination of Heterotrophic Plate Count
 - b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
 2. References:
 - a. Philippine National Standards for Drinking Water, 2017
 - b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 3. Result of examination **specifically** relates to samples as received



Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303



Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0323E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	06/03/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	06/03/2020
		Date Completed :	06/05/2020


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform		Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)			
Salome Pallorca	P-2 Sta. Maria	June 03, 2020 08:10 AM	<1	<1.1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
1. Test method used:
 - a. Pour Plate Method for the determination of Heterotrophic Plate Count
 - b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
 2. References:
 - a. Philippine National Standards for Drinking Water, 2017
 - b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 3. Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
 Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
 Head of the Laboratory, PRC No. 64242

