

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

DOH Accreditation #03-001-18-LW-1

Telephone: (044) 463-1646 / 47 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0394A

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

07/06/2020

Address

DON PALMACIO AVE., POB SUR, LICAB,

Date Analyzed:

07/06/2020

NUEVA ECIJA

Date Completed:

07/08/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address Date and Time of Sampling	Date and Time of	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
•		Sampling		(MPN/100mL)		
Neri Esperanza	San Cristobal	July 06, 2020 09:07 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF

3. Result of examination specifically relates to samples as received

Analyst, PAM No. 18-00303

CCWDLAB-FORM02-01 Page 1 of 6

NOT VALID WITHOUT DRY SEAL

Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-001-18-LW-1

Telephone: (044) 463-1646 / 47 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0394B

Owner/Manager:

ANNE LORELIE DL. LAURETA

07/06/2020

Address

DON PALMACIO AVE., POB SUR, LICAB,

077007202

NUEVA ECIJA

Date Analyzed:

Date Received:

07/06/2020

Date Completed:

07/08/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampling	(Est. CFU/mL) (MPN/100mL)		100mL)	,
April Tumacder	P3-Villarosa	July 06, 2020 09:20 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMicro Analyst, PAM No. 18-00303

CCWDLAB-FORM02-01 Page 2 of 6

NOT VALID WITHOUT DRY SEAL

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-001-18-LW-1

Telephone: (044) 463-1646 / 47 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0394C

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received : 07/06/2020

Address

DON PALMACIO AVE., POB SUR, LICAB,

01700/2020

NUEVA ECIJA

Date Analyzed :

07/06/2020

Date Completed:

07/08/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	1	
		Sampling	Sampling	(Est. CFU/mL)	(MPN/100mL)		
Emilie Aqı	uino	Pob. Norte	July 06, 2020 09:00 AM	1	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

ronica A. Presentacion, RMicr Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

CCWDLAB-FORM02-01 Page 3 of 6

NOT VALID WITHOUT DRY SEAL



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

DOH Accreditation #03-001-18-LW-1

(7) Telephone: (044) 463-1646 / 47 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0394D

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received: 07/06/2020

Address

DON PALMACIO AVE., POB SUR, LICAB,

NUEVA ECIJA

Date Analyzed: Date Completed: 07/06/2020 07/08/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampling	(Est. CFU/mL)			,
Zeus Antonio	Pob. Sur	July 06, 2020 09:15 AM	2	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF

3. Result of examination specifically relates to samples as received

Ahalyst, PAM No. 18-00303

CCWDLAB-FORM02-01 Page 4 of 6

NOT VALID WITHOUT DRY SEAL

Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-001-18-LW-1

Telephone: (044) 463-1646 / 47 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0394E

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received : 07/06/2020

Address

DON PALMACIO AVE., POB SUR, LICAB,

Date Analyzed :

07/06/2020

NUEVA ECIJA

Date Completed:

07/08/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address Date and Time of Sampling		Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		(Est. CFU/mL)	(MPN/100mL)		*	
Elma Galido	P-3 Sta. Maria	July 06, 2020 09:15 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1,1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

orica A. Presentacion, RMicro Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

CCWDLAB-FORM02-01 Page 5 of 6

NOT VALID WITHOUT DRY SEAL



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-001-18-LW-1

Telephone: (044) 463-1646 / 47 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

20-0394F

Owner/Manager:

ANNE LORELIE DL. LAURETA

07/06/2020

Address

DON PALMACIO AVE., POB SUR, LICAB,

NUEVA ECIJA

Date Analyzed :

Date Received:

07/06/2020

Date Completed:

07/08/2020

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	
		Sampling	(Est. CFU/mL)	(MPN/100mL)		
Lilibeth Enriquez	P-6 Sta. Maria	July 06, 2020 09:25 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMicro Analyst, PAM No. 18-00303

CCWDLAB-FORM02-01 Page 6 of 6

NOT VALID WITHOUT DRY SEAL

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242