Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-001-18-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0636A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	10/12/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	10/12/2020
		Date Completed :	10/14/2020

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Adelina Cadena	Purok 3, Villarosa	October 12, 2020 10:46 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

NOT VALID WITHOUT DRY SEAL

CCWDLAB-FORM02-01
Effective: February 17, 2020

Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-001-18-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0625B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	10/06/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	10/06/2020
		Date Completed :	10/08/2020

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Ligaya Juliano	Pob. Sur	October 06, 2020 09:30 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

NOT VALID WITHOUT DRY SEAL

CCWDLAB-FORM02-01
Effective: February 17, 2020

Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-001-18-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0636B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	10/12/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	10/12/2020
		Date Completed :	10/14/2020

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Lorelie Sangil	San Casimiro	October 12, 2020 11:20 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

NOT VALID WITHOUT DRY SEAL

CCWDLAB-FORM02-01
Effective: February 17, 2020

Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-001-18-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0625C
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	10/06/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	10/06/2020
		Date Completed :	10/08/2020

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Elizabeth Dela Peña	Purok 2, Sta. Maria	October 06, 2020 09:10 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

NOT VALID WITHOUT DRY SEAL

CCWDLAB-FORM02-01
Effective: February 17, 2020

Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-001-18-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0625D
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	10/06/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	10/06/2020
		Date Completed :	10/08/2020

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Aldrin Garcia	Purok 5, Sta. Maria	October 06, 2020 09:10 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

NOT VALID WITHOUT DRY SEAL

CCWDLAB-FORM02-01
Effective: February 17, 2020

Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-001-18-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0625E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	10/06/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	10/06/2020
		Date Completed :	10/08/2020

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Esperanza Neri	Purok 4 San Cristobal	October 06, 2020 09:24 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

NOT VALID WITHOUT DRY SEAL

CCWDLAB-FORM02-01
Effective: February 17, 2020