



**Cabanatuan  
City  
Water  
District**

# WATER TESTING LABORATORY

✉ 229 Maharlika Road, Dicarma District,  
Cabanatuan City, Philippines

☎ Telephone: (044) 463-1646 / 47 local 505

DOH Accreditation  
#03-001-18-LW-1

@ ccwdwaterlab@gmail.com

## WATER MICROBIOLOGY ANALYSIS REPORT

Client : LICAB WATER DISTRICT  
Owner/Manager : ANNE LORELIE DL. LAURETA  
Address : DON PALMACIO AVE., POB SUR, LICAB,  
NUEVA ECIJA

WMAR No : 20-0748B  
Date Received : 12/02/2020  
Date Analyzed : 12/02/2020  
Date Completed : 12/04/2020

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Xeuz Antonio	Pob. Sur	December 02, 2020 09:30 AM	120	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

**Veronica A. Presentation, RMicro**  
Analyst, PAM No. 18-00303

**Susana P. Quiaolt, MD, FPSP**  
Head of the Laboratory, PRC No. 64242





**Cabanatuan  
City  
Water  
District**

# WATER TESTING LABORATORY

✉ 229 Maharlika Road, Dicarma District,  
Cabanatuan City, Philippines

☎ Telephone: (044) 463-1646 / 47 local 505

DOH Accreditation  
#03-001-18-LW-1

@ ccwdwaterlab@gmail.com

## WATER MICROBIOLOGY ANALYSIS REPORT

Client : LICAB WATER DISTRICT  
Owner/Manager : ANNE LORELIE DL. LAURETA  
Address : DON PALMACIO AVE., POB SUR, LICAB,  
NUEVA ECIJA

WMAR No : 20-0748C  
Date Received : 12/02/2020  
Date Analyzed : 12/02/2020  
Date Completed : 12/04/2020

Physical Characteristics : Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Salome Pallarco	Sta. Maria	December 02, 2020 09:30 AM	5	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA.AWWA. WEF
  - Result of examination **specifically** relates to samples as received

**Veronica A. Presentacion, RMicro**  
Analyst, PAM No. 18-00303

**Susana P. Quiaolt, MD, FPSP**  
Head of the Laboratory, PRC No. 64242



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0748F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	12/02/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	12/02/2020
		Date Completed :	12/04/2020


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Diane Tagasa	Villarosa	December 02, 2020 09:40 AM	110	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
**Veronica A. Presentation, RMicro**  
 Analyst, PAM No. 18-00303

  
**Susana P. Quiaon, MD, FPSP**  
 Head of the Laboratory, PRC No. 64242



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0754A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	12/07/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	12/07/2020
		Date Completed :	12/09/2020


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Romnick Garcia	Sta. Maria	December 07, 2020 09:12 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
**Veronica A. Presentacion, RMicro**  
Analyst, PAM No. 18-00303

  
**Susana P. Quiaolt, MD, FPSP**  
Head of the Laboratory, PRC No. 64242



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	20-0754B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	12/07/2020
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	12/07/2020
		Date Completed :	12/09/2020

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Emilie Aquino	Pob. Norte	December 07, 2020 09:33 AM	3	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

Note :

- Test method used:
  - Pour Plate Method for the determination of Heterotrophic Plate Count
  - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
- References:
  - Philippine National Standards for Drinking Water, 2017
  - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiason, MD, FPSP  
Head of the Laboratory, PRC No. 64242



## WATER MICROBIOLOGY ANALYSIS REPORT

Client : LICAB WATER DISTRICT  
Owner/Manager : ANNE LORELIE DL. LAURETA  
Address : DON PALMACIO AVE., POB SUR, LICAB,  
NUEVA ECIJA

WMAR No : 20-0754C  
Date Received : 12/07/2020  
Date Analyzed : 12/07/2020  
Date Completed : 12/09/2020


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Fortunata Concepcion	San Cristobal	December 07, 2020 09:30 AM	<1	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
**Veronica A. Presentation, RMicro**  
Analyst, PAM No. 18-00303

  
**Susana P. Quijano, MD, FPSP**  
Head of the Laboratory, PRC No. 64242