

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines Telephone: (044) 463-1646 / 47 local 505 DOH Accreditation #03-001-18-LW-1 @ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No:	21-0102A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	02/03/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	02/03/2021
		Date Completed :	02/05/2021

Physical Characteristics: Sample is clear, with no foreign matter

Sample Name Address	Address Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli		
		Sampling	(Est. CFU/mL)	(MPN/100mL)		
Elaija Vetuz	Purok 5, Sta. Maria	February 03, 2021 09:00 AM	410	<1.1	<1.1	PASSED
	PNSDWI	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

1. Test method used:

Note:

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms

2. References:

a. Philippine National Standards for Drinking Water, 2017

b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF

3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMicro

Analyst, PAM No. 18-00303

Page 1 of 6 NOT VALID WITHOUT DRY SEAL

aoit, MD. FPSP Susana P. Head of the Laboratory, PRC No. 64242

CCWDLAB-FORM02-01 Effective: February 17, 2020



 229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505 DOH Accreditation
#03-001-18-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No:	21-0102B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	02/03/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	02/03/2021
		Date Completed :	02/05/2021

Physical Characteristics :

Sample is clear, with no foreign matter

Sample Name	Address Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks	
	Address	Sampling				100mL)
Gloria S. Rivera	Purok 1, Sta. Maria	February 03, 2021 09:10 AM	390	<1.1	<1.1	PASSED
	PNSDWI	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

1. Test method used:

Note :

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms

2. References:

a. Philippine National Standards for Drinking Water, 2017

b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF

3. Result of examination specifically relates to samples as received

Vern RMicro Analyst, PAM No. 18-00303

Page 2 of 6 NOT VALID WITHOUT DRY SEAL

aolt, MD, FPSP Susana P Head of the Laboratory, PRC No. 64242

CCWDLA8-FORM02-01 Effective: February 17, 2020



🔀 229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines Telephone: (044) 463-1646 / 47 local 505

DOH Accreditation #03-001-18-LW-1 @ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

LICAB WATER DISTRICT	WMAR No :	21-0102C
ANNE LORELIE DL. LAURETA	Date Received :	02/03/2021
DON PALMACIO AVE., POB SUR, LICAB,	Date Analyzed :	02/03/2021
	Date Completed :	02/05/2021
	ANNE LORELIE DL. LAURETA	ANNE LORELIE DL. LAURETA Date Received : DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA Date Analyzed :

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks	
		(Est. CFU/mL)	(MPN/100mL)		ide :	
Emilie Del Rosario	P. Sur, Licab, N.E.	February 03, 2021 09:05 AM	2	<1.1	<1.1	PASSED
	PNSDWI	Limits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

1. Test method used:

Note :

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms

2. References:

a. Philippine National Standards for Drinking Water, 2017

b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF 3. Result of examination specifically relates to samples as received

entacion, RMicro

Analyst, PAM No. 18-00303

Page 3 of 6 NOT VALID WITHOUT DRY SEAL

CCWDLAB-FORM02-01 Effective: February 17, 2020



🔀 229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines (?) Telephone: (044) 463-1646 / 47 local 505 DOH Accreditation #03-001-18-LW-1 @ ccwdwaterlab@amail.com

WATER MICROBIOLOGY ANALYSIS REPORT

LICAB WATER DISTRICT	WMAR No:	21-0102D
ANNE LORELIE DL. LAURETA	Date Received :	02/03/2021
DON PALMACIO AVE., POB SUR, LICAB,	Date Analyzed :	02/03/2021
NUEVA ECIJA	Date Completed :	02/05/2021
	ANNE LORELIE DL. LAURETA	ANNE LORELIE DL. LAURETA Date Received : DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA Date Analyzed :

Physical Characteristics: Sample is clear, with no foreign matter

Sample Name Ad	Address Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks	
		Sampling	(Est. CFU/mL)	(MPN/100mL)		
Nora Bumanlag	P. Norte, Licab, N.E.	February 03, 2021 09:15 AM	1	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

1. Test method used:

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms

2. References:

a. Philippine National Standards for Drinking Water, 2017

b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF 3. Result of examination specifically relates to samples as received

Micro Vor Analyst, PAM No. 18-00303

Page 4 of 6 NOT VALID WITHOUT DRY SEAL

aolt. MD. FPSP Susana P Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines (7) Telephone: (044) 463-1646 / 47 local 505 DOH Accreditation #03-001-18-LW-1 @ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No:	21-0102D
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	02/03/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	02/03/2021
		Date Completed :	02/05/2021

Physical Characteristics :

Sample is clear, with no foreign matter

Sample Name Addres	Address Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks	
		Sampling	(Est. CFU/mL)	(MPN/100mL)		
Nora Bumanlag	P. Norte, Licab, N.E.	February 03, 2021 09:15 AM	1	<1.1	<1.1	PASSED
	PNSDWL	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

1. Test method used:

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms

2. References:

a. Philippine National Standards for Drinking Water, 2017

b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF

3. Result of examination specifically relates to samples as received

Vera RMicro Analyst, PAM No. 18-00303

Page 4 of 6 NOT VALID WITHOUT DRY SEAL

Quiaolt, MD, FPSP Susana P. Head of the Laboratory, PRC No. 64242



 229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505 #03-001-18-LW-1 ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No:	21-0102E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	02/03/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	02/03/2021
		Date Completed :	02/05/2021

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli		
		Sampling	(Est. CFU/mL)	(MPN/100mL)		
Fortunata Concepcion	San Cristobal, Licab, N.E., P.4	February 03, 2021 09:14 AM	<1	<1.1	<1.1	PASSE
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

1. Test method used:

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total and Fecal/Thermotolerant coliforms

2. References:

a. Philippine National Standards for Drinking Water, 2017

b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF 3. Result of examination specifically relates to samples as received

cion, RMicro Veror Analyst, PAM No. 18-00303

Page 5 of 6 NOT VALID WITHOUT DRY SEAL

liaolt, MD, FPSP Susana P Head of the Laboratory, PRC No. 64242