Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-003-21-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0377A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	06/02/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	06/02/2021
		Date Completed :	06/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Manuel Sarmiento	Pob. Norte, Licab, N.E.	June 02, 2021 07:25 AM	17	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-003-21-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0377B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	06/02/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	06/02/2021
		Date Completed :	06/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Lorelie Sangil	San Casimiro, Licab, N.E.	June 02, 2021 07:40 AM	6	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-003-21-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0377C
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	06/02/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	06/02/2021
		Date Completed :	06/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Susan Reyes	Villarosa, Licab, N.E.	June 02, 2021 08:00 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-003-21-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0377D
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	06/02/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	06/02/2021
		Date Completed :	06/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Dindo Dela Cruz	San Cristobal, Licab, N.E.	June 02, 2021 07:51 AM	12	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Cabanatuan City Water District
19 74

WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505
DOH Accreditation #03-003-21-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0377F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	06/02/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	06/02/2021
		Date Completed :	06/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform (MPN/100mL)	Thermotolerant Coliform / *E. coli* (MPN/100mL)	Remarks
Reyglam Apellido	P.5 Sta. Maria, Licab, N.E.	June 02, 2021 07:50 AM	60	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

1. *Test method used:*
   a. *Pour Plate Method for the determination of Heterotrophic Plate Count*
   b. *Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli*
2. *References:*
   a. *Philippine National Standards for Drinking Water, 2017*
   b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF*
3. *Result of examination **specifically** relates to samples as received*

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.