

WATER TESTING LABORATORY

 229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505

DOH Accreditation
#03-003-21-LW-1
ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0510A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/04/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/04/2021
		Date Completed :	08/06/2021

Physical Characteristics : Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count	Total Coliform Thermotolerant Coliform / E. coli	1	
		Sampling	(Est. CFU/mL)	(MPN/	100mL)	
Zeus Antonio	Pob. Sur, Licab, N.E.	August 04, 2021 08:30 AM	2	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

1 Test method used

2. References:

Note :

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli

a. Philippine National Standards for Drinking Water, 2017

b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Veron RMicro ica A Analyst, PAM No. 18-00303

Quiaoit, MD, FPSP Susana P. Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-02 Effective: February 17, 2021 This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 1 of 6



WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines #03-003-21-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Telephone: (044) 463-1646 / 47 local 505

Client :	LICAB WATER DISTRICT	WMAR No :	21-0510B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/04/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/04/2021
		Date Completed :	08/06/2021

Physical Characteristics : Sample is clear, with no foreign matter

()

Sample Name	Address	Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampling	(Est. CFU/mL)	(MPN/	100mL)	
Emilie Aquino	Pob. Norte, Licab, N.E.	August 04, 2021 08:42 AM	<1	<1.1	<1.1	PASSED
	PNSDW	Limits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli

2. References:

1. Test method used:

- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

ica A. Presentacion, RMicro Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-02 Effective: February 17, 2021

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 2 of 6



WATER TESTING LABORATO 229 Maharlika Road, Dicarma District, \sim Cabanatuan City, Philippines

DOH Accreditation #03-003-21-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Telephone: (044) 463-1646 / 47 local 505

Client :	LICAB WATER DISTRICT	WMAR No :	21-0510C
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/04/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/04/2021
		Date Completed :	08/06/2021

Physical Characteristics: Sample is clear, with no foreign matter

()

Sample Name Address		Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	1
		Sampling	(Est. CFU/mL)	(MPN/	100mL)	
Eladia Vetuz	P.5 Sta. Maria, Licab, N.E.	August 04, 2021 08:45 AM	<1	<1.1	<1.1	PASSED
	PNSDW	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

1. Test method used:

2. References:

Note :

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli

a. Philippine National Standards for Drinking Water, 2017

- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

A. Presentacion. RMicro Analyst, PAM No. 18-00303

P. Quiaoit, MD, FPSP Susa Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-02 Effective: February 17, 2021 This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 3 of 6



WATER TESTING LABORATORY

 229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505 #03-003-21-LW-1

Ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0510D
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/04/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/04/2021
		Date Completed :	08/06/2021

Physical Characteristics : Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampling	(Est. CFU/mL)	(MPN/	100mL)	
Amor Yango	P.3 Sta. Maria, Licab, N.E.	August 04, 2021 08:50 AM	5	<1.1	<1.1	PASSED
	PNSDW I	_imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

1. Test method used:

2. References:

Note :

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli

a. Philippine National Standards for Drinking Water, 2017

b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-02 Effective: February 17, 2021

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 4 of 6



 229 Maharilika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505

WATER TESTING LABORATOR

#03-003-21-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0510E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/04/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/04/2021
		Date Completed :	08/06/2021

Physical Characteristics : Sample is clear, with no foreign matter

Sample Name Addre	Address	Date and Time of	Heterotrophic Plate Count	Total Coliform Thermotolerant Coliform / E. coli		
		Sampling	(Est. CFU/mL)	(MPN/	(MPN/100mL)	
Fortunata Concepcion	P.4 San Cristobal, Licab, N.E.	August 04, 2021 09:08 AM	3	<1.1	<1.1	PASSED
	PNSDW	Limits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter MPN/100mL = Most Probable Number per 100 mililiters

1. Test method used:

2. References:

Note :

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli

Philippine National Standards for Drinking Water, 2017

b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

RMicro Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-02 Effective: February 17, 2021 This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 5 of 6



WATER TESTING LABORATOR

 229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines
Telephone: (044) 463-1646 / 47 local 505 #03-003-21-LW-1

Ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0510F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/04/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/04/2021
		Date Completed :	08/06/2021

Physical Characteristics : Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count	LOTAL CONTORM	Thermotolerant Coliform / E. coli	Remarks
		Sampling	(Est. CFU/mL)	(MPN/	(MPN/100mL)	
Adelina Cadena	Villarosa, Licab, N.E.	August 04, 2021 09:25 AM	<1	<1.1	<1.1	PASSED
	PNSDW	_imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note :

a. Pour Plate Method for the determination of Heterotrophic Plate Count

b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli

2. References:

1. Test method used:

- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

RMicro Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-02 Effective: February 17, 2021

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 6 of 6