

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0581A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	09/06/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	09/06/2021
		Date Completed :	09/08/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Purification Tugawin	Sta. Maria, Licab, N.E.	September 06, 2021 08:20 AM	10	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

## WATER MICROBIOLOGY ANALYSIS REPORT

Client : LICAB WATER DISTRICT

Owner/Manager : ANNE LORELIE DL. LAURETA

Address : DON PALMACIO AVE., POB SUR, LICAB,  
NUEVA ECIJA

WMAR No : 21-0581B

Date Received : 09/06/2021

Date Analyzed : 09/06/2021

Date Completed : 09/08/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Amor Yango	Sta. Maria, Licab, N.E.	September 06, 2021 08:35 AM	240	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0581C
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	09/06/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	09/06/2021
		Date Completed :	09/08/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Robert Miguel	San Cristobal, Licab, N.E.	September 06, 2021 08:38 AM	94	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0581D
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	09/06/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	09/06/2021
		Date Completed :	09/08/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
April Tumacder	Villarosa, Licab, N.E.	September 06, 2021 08:54 AM	12	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0581E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	09/06/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	09/06/2021
		Date Completed :	09/08/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Eliseo E. Sarmiento	Pob. Norte, Licab, N.E.	September 06, 2021 09:04 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	21-0581F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	09/06/2021
Address	DON PALMACIO AVE., POB SUR, LICAB, NUEVA ECIJA	Date Analyzed :	09/06/2021
		Date Completed :	09/08/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Lorelie Sangil	San Cristobal, Licab, N.E.	September 06, 2021 09:25 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal