

VATER TESTING LABORATOR

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

(7) Telephone: (044) 463-1643 local 246

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0316A

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

04/02/2025

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

04/02/2025

NUEVA ECIJA

Date Completed:

04/04/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		, ,	(Est. CFU/mL)	(MPN/100mL)		
April Tumacder	Villarosa, Licab, N.E.	April 02, 2025 07:58 AM	17	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2 References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303, PRC no. 2215

Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



/ATER TESTING LABORATOR

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

(7) Telephone: (044) 463-1643 local 246

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0316B

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

04/02/2025

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

04/02/2025

NUEVA ECIJA

Date Completed:

04/04/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
			(Est. CFU/mL)	(MPN/	(MPN/100mL)	
Eduardo Flores	San Cristobal, Licab, N.E.	April 02, 2025 08:15 AM	6	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303, PRC no. 2215

Head of the Laboratory, PRC No. 64242



WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 463-1643 local 246

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0316C

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

04/02/2025

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

04/02/2025

NUEVA ECIJA

Date Completed:

04/04/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)		Thermotolerant Coliform / E. coli 100mL)	Remarks
Ruth M. Agustin	Sta. Maria, Licab, N.E.	April 02, 2025 08:06 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Veronica A. Presentación, RMicro, PFT Analyst, PAM No. RM 18-00303, PRC no. 2215 Susana . Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-04

Effective: January 3, 2025



WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 463-1643 local 246

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :

LICAB WATER DISTRICT

WMAR No:

25-0316D

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

04/02/2025

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

04/02/2025

NUEVA ECIJA

Date Completed :

04/04/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name Address	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	coli	Remarks	
				(MPN/100mL)		
Marciano Cabading	Sta. Maria, Licab, N.E.	April 02, 2025 08:15 AM	2	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Verofica A. Presentación, RMicro, PFT Analyst, PAM No. RM 18-00303, PRC no. 2215 Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-04

Effective: January 3, 2025



WATER TESTING LABORATORY

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 463-1643 local 246

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0316E

Owner/Manager:

ANNE LORELIE DL. LAURETA

04/02/2025

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

Date Received:

04/02/2025

NUEVA ECIJA

Date Completed :

04/04/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)		Thermotolerant Coliform / E. coli 100mL)	Remarks
Pob. Sur Pumping Station	Pob. Sur, Licab, N.E.	April 02, 2025 08:25 AM	2	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Veronica A. Presentación, RMicro, PFT Analyst, PAM No. RM 18-00303, PRC no. 2215

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



ATER TESTING LABORATOR

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines (C) Telephone: (044) 463-1643 local 246

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0316F

Owner/Manager:

ANNE LORELIE DL. LAURETA

04/02/2025

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

Date Received:

04/02/2025

NUEVA ECIJA

Date Completed:

04/04/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)		Thermotolerant Coliform / E. coli	Remarks
				(MPN/100mL)		
Modesa Sarmiento	Pob. Norte, Licab, N.E.	April 02, 2025 08:38 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303, PRC no. 2215

Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



ATER TESTING LABORATOR

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

DOH Accreditation #03-002-2426-LW-1

Telephone: (044) 463-1643 local 246

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0316G

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

04/02/2025

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

04/02/2025

NUEVA ECIJA

Date Completed:

04/04/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count		Thermotolerant Coliform / E. coli	Remarks
	Jumpining	(Est. CFU/mL)	(MPN/100mL)			
Lorelie Sangil	San Casimiro, Licab, N.E.	April 02, 2025 09:10 AM	6	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant h
- Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, RAM No. RM 18-00303, PRC no. 2215

Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242