

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0302A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	04/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	04/03/2024
		Date Completed :	04/05/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
SALOME PALLARCO	STA. MARIA, LICAB, NUEVA ECIJA	April 03, 2024 07:52 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E. coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. RM 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB FORM02-03  
Effective: January 4, 2024

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 1 of 7

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0302B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	04/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	04/03/2024
		Date Completed :	04/05/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
				(MPN/100mL)		
AMOR YANGO	STA. MARIA, LICAB, NUEVA ECIJA	April 03, 2024 08:01 AM	3	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. RM 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0302C
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	04/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	04/03/2024
		Date Completed :	04/05/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
FORTUNATA CONCEPCION	SAN CRISTOBAL, LICAB, NUEVA ECIJA	April 03, 2024 07:40 AM	11	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentation, RMITRO  
Analyst, PAM No. RM 18-00303

  
Susana J. Quilaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-03  
Effective: January 4, 2024

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 3 of 7



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0302D
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	04/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	04/03/2024
		Date Completed :	04/05/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
APRIL TUMACDER	VILLAROSA, LICAB, NUEVA ECIJA	April 03, 2024 08:16 AM	23	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentation, Micro  
Analyst, PAM No. RM 18-00303

  
Susana P. Quilait, MD, FPSP  
Head of the Laboratory, PRC No. 64242

**Not Valid Without Dry Seal**

CCWDLAB-FORM02-03  
Effective: January 4, 2024

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 4 of 7

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0302E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	04/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	04/03/2024
		Date Completed :	04/05/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
LIGAYA JULIANO	POBLACION SUR, LICAB, NUEVA ECIJA	April 03, 2024 08:00 AM	310	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. RM 18-00303

  
Susana F. Quilaolt, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-03  
Effective: January 4, 2024

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0302F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	04/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	04/03/2024
		Date Completed :	04/05/2024

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
MODESTA SARMIENTO	POBLACION NORTE, LICAB, NUEVA ECIJA	April 03, 2024 08:12 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, B.Micro  
Analyst, PAM No. RM 18-00303

  
Susana J. Quilaolt, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-03  
Effective: January 4, 2024

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 6 of 7



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0302G
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	04/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	04/03/2024
		Date Completed :	04/05/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
BRGY. HALL	SAN CASIMIRO, LICAB, NUEVA ECIJA	April 03, 2024 08:28 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentation, RMicro  
Analyst, PAM No. RM 18-00303

  
Susana F. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal