

## WATER MICROBIOLOGY ANALYSIS REPORT

Client : LICAB WATER DISTRICT  
Owner/Manager : ANNE LORELIE DL. LAURETA  
Address : REAL ST., POBLACION SUR, LICAB,  
NUEVA ECIJA

WMAR No : 24-0613A  
Date Received : 08/06/2024  
Date Analyzed : 08/06/2024  
Date Completed : 08/08/2024

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
				(MPN/100mL)		
Emilou Valdez	Sta. Maria, Licab, N.E.	August 06, 2024 08:02 AM	7	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. RM 18-00303

  
Sucana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0613B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/06/2024
		Date Completed :	08/08/2024

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Salome Pallarco	Sta. Maria, Licab, N.E.	August 06, 2024 08:21 AM	3	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

Note :

- Test method used:
  - Bour Plate Method for the determination of Heterotrophic Plate Count
  - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- References:
  - Philippine National Standards for Drinking Water, 2017
  - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. RM 18-00303

  
Susana F. Quilaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0613C
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/06/2024
		Date Completed :	08/08/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Dindo Dela Cruz	San Cristobal, Licab, N.E.	August 06, 2024 06:59 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. RM 18-00303

  
Susana F. Quilaot, MD, FPSP  
Head of the Laboratory, PRC No. 64242



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0613D
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/06/2024
		Date Completed :	08/08/2024

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Alona Hadap	Villarosa, Licab, N.E.	August 06, 2024 07:19 AM	2	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentation, RMicro  
Analyst, PAM No. RM 18-00303

  
Susana P. Quilaot, MD, FPSP  
Head of the Laboratory, PRC No. 64242

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0613E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/06/2024
		Date Completed :	08/08/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Sylvia De Jesus	San Juan, Licab, N.E.	August 06, 2024 08:08 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
1. Test method used:
    - a. Pour Plate Method for the determination of Heterotrophic Plate Count
    - b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  2. References:
    - a. Philippine National Standards for Drinking Water, 2017
    - b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  3. Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. RM 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0613F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/06/2024
		Date Completed :	08/08/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Rosalinda Cueco	Pob Sur, Licab, N.E.	August 06, 2024 08:24 AM	7	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. RM 18-00303

  
Susana P. Quilaot, MD, FPSP  
Head of the Laboratory, PRC No. 64242



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0613G
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	08/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	08/06/2024
		Date Completed :	08/08/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Emilie Aquino I	Pob Norte, Licab, N.E.	August 06, 2024 08:40 AM	40	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. RM 18-00303

  
Susana F. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242