

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 463-1643 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0924B

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

12/04/2024

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

12/04/2024

Address **NUEVA ECIJA**

Date Completed:

12/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Jampung	(Est. CFU/mL)	(MPN/	/100mL)	
Rosalinda Coeco	Pob. Sur, Licab, N.E.	December 04, 2024 07:44 AM	<1	<1,1	<1,1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note .

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant
- Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

DOH Accreditation #03-002-2426-LW-1

Telephone: (044) 463-1643 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0944

Owner/Manager:

ANNE LORELIE DL. LAURETA

12/10/2024

Address

REAL ST., POBLACION SUR, LICAB,

NUEVA ECIJA

Date Analyzed:

Date Received:

12/10/2024

Date Completed:

12/12/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Total Coliform Thermotolerant Coliform / E. coli		Remarks
		Jumping	(MPN/	100mL)	
POBLACION SUR PUMPING STATION	POBLACION SUR, LICAB, NUEVA ECIJA	December 10, 2024 08:05 AM	<1.1	<1.1	PASSED
	PNSI	<1.1	<1.1		

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant
- Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 463-1643 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0924C

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received : 12/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

12/04/2024

NUEVA ECIJA

Date Analyzed:

12/04/2024

Date Completed :

12/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
			(Est. CFU/mL)	(MPN/	00mL)	
Sta. Maria PS	Sta. Maria, Licab, N.E.	December 04, 2024 07:18 AM	8	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- Colifori
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Verginica A. Presentacion, Rifficro Analyst, PAM No. RM 18-00303

Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City. Philippines

Telephone: (044) 463-1643 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0924D

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

Address

REAL ST., POBLACION SUR, LICAB,

12/04/2024

NUEVA ECIJA

Date Analyzed:

12/04/2024

Date Completed:

12/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count		Thermotolerant Coliform / E. coli	Remarks
		,	(Est. CFU/mL)	(MPN/	00mL)	
Marciano Cabanding	Sta. Maria, Licab, N.E.	December 04, 2024 07:20 AM	5	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

1. Test method used:

2. References:

- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

yst, PAM No. RM 18-00303.

Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

(7) Telephone: (044) 463-1643 local 505

III DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0924E

Owner/Manager:

ANNE LORELIE DL. LAURETA

12/04/2024 Date Received:

REAL ST., POBLACION SUR, LICAB,

Address **NUEVA ECIJA** Date Analyzed: Date Completed: 12/04/2024 12/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sumpling	(Est. CFU/mL)	(MPN/	00mL)	
San Casimiro PS	San Casimiro, Licab, N.E.	December 04, 2024 08:03 AM	1	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017 a.
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 463 1643 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0924F

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received: 12/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

NUEVA ECIJA

Date Analyzed :
Date Completed :

12/04/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count		Thermotolerant Coliform / E. coli	Remarks
		Jumpung	(Est. CFU/mL)	(MPN/		
San Cristobal PS	San Cristobal, Licab, N.E.	December 04, 2024 08:16 AM	<1	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Susana F. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



Date Completed:

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines #03-002-2426-LW-1

12/06/2024

Telephone: (044) 463-1643 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client: LICAB WATER DISTRICT WMAR No : 24-0924G

Owner/Manager: ANNE LORELIE DL. LAURETA Date Received: 12/04/2024

Address REAL ST., POBLACION SUR, LICAB, Date Analyzed: 12/04/2024

NUEVA ECIJA

Physical Characteristics : Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampung	(Est. CFU/mL)	(MPN/	00mL)	
April Tumacder	Villa Rosa, Licab, N.E.	December 04, 2024 08:31 AM	28	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter MPN/100mL = Most Probable Number per 100 milliliters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMicro Analyst, PAM No. RM 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242