

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0112A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	02/05/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	02/05/2024
		Date Completed :	02/07/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Salome Pallarco	Sta. Maria, Licab, N.E.	February 05, 2024 08:07 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quilaolt, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-03
Effective: January 4, 2024

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 1 of 7

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0112B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	02/05/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	02/05/2024
		Date Completed :	02/07/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Pablo Santos	Sta. Maria, Licab, N.E.	February 05, 2024 08:15 AM	2	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quiaolt, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-03
Effective: January 4, 2024

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 2 of 7

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0112C
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	02/05/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	02/05/2024
		Date Completed :	02/07/2024

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
				(MPN/100mL)		
Dindo Dela Cruz	San Cristobal, Licab, N.E.	February 05, 2024 08:09 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter


MPN/100mL = Most Probable Number per 100 milliliters

- Note :
1. Test method used:
 - a. Pour Plate Method for the determination of Heterotrophic Plate Count
 - b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 2. References:
 - a. Philippine National Standards for Drinking Water, 2017
 - b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 3. Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



WATER MICROBIOLOGY ANALYSIS REPORT

Client : LICAB WATER DISTRICT
Owner/Manager : ANNE LORELIE DL. LAURETA
Address : REAL ST., POBLACION SUR, LICAB,
NUEVA ECIJA

WMAR No : 24-0112D
Date Received : 02/05/2024
Date Analyzed : 02/05/2024
Date Completed : 02/07/2024

Physical Characteristics : Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
April Tumacder	Villarosa, Licab, N.E.	February 05, 2024 08:30 AM	4	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received

Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0112E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	02/05/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	02/05/2024
		Date Completed :	02/07/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Ligaya Juliano	Pob. Sur, Licab, N.E.	February 05, 2024 08:02 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
1. Test method used:
 - a. Pour Plate Method for the determination of Heterotrophic Plate Count
 - b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 2. References:
 - a. Philippine National Standards for Drinking Water, 2017
 - b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 3. Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quiñones, MD, FPSP
Head of the Laboratory, PRC No. 64242



WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0112F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	02/05/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	02/05/2024
		Date Completed :	02/07/2024

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Emilie Aquino	Pob. Norte, Licab, N.E.	February 05, 2024 08:16 AM	88	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
1. Test method used:
 - a. Pour Plate Method for the determination of Heterotrophic Plate Count
 - b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 2. References:
 - a. Philippine National Standards for Drinking Water, 2017
 - b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 3. Result of examination **specifically** relates to samples as received

Veronica A. Presentacion, RMicro
Analyst, PAM No. RM 18-00303

Susana F. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0112G
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	02/05/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIA	Date Analyzed :	02/05/2024
		Date Completed :	02/07/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
San Casimiro Brgy. Hall	San Casimiro, Licab, N.E.	February 05, 2024 08:36 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242