

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0004A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/03/2024
		Date Completed :	01/05/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
DINDO DELA CRUZ	SAN CRISTOBAL, LICAB, NUEVA ECIJA	January 03, 2024 07:45 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0004B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/03/2024
		Date Completed :	01/05/2024

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
APRIL TUMACDER	VILLAROSA, LICAB, NUEVA ECIJA	January 03, 2024 08:03 AM	35	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0004C
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/03/2024
		Date Completed :	01/05/2024

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
ELMA GARRIDO	STA. MARIA, LICAB, NUEVA ECIJA	January 03, 2024 08:15 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentation, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0004D
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/03/2024
		Date Completed :	01/05/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
RUTH M. AGUSTIN	STA. MARIA, LICAB, NUEVA ECIJA	January 03, 2024 08:25 AM	4	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0004E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/03/2024
		Date Completed :	01/05/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
ROSALINDA CUECO	POBLACION SUR, LICAB, NUEVA ECIJA	January 03, 2024 08:06 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentation, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0004F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/03/2024
		Date Completed :	01/05/2024

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
				(MPN/100mL)		
LORELIE SANGIL	SAN CASIMIRO, LICAB, NUEVA ECIJA	January 03, 2024 08:22 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

Veronica A. Presentation, RMicro  
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



## WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0004G
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/03/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/03/2024
		Date Completed :	01/05/2024

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
EMILIE AQUINO I	POBLACION NORTE, LICAB, NUEVA ECIJA	January 03, 2024 08:45 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
    - Pour Plate Method for the determination of Heterotrophic Plate Count
    - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
  - References:
    - Philippine National Standards for Drinking Water, 2017
    - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
  - Result of examination **specifically** relates to samples as received

  
Veronica A. Presentacion, RMicro  
Analyst, PAM No. 18-00303

  
Susana P. Quiaoit, MD, FPSP  
Head of the Laboratory, PRC No. 64242

**Not Valid Without Dry Seal**

CCWDLAB-FORM02-02  
Effective: February 17, 2021

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 7 of 7