

229 Maharlika Road, Dicarma District. Cabanatuan City, Philippines

Telephone: (044) 951-6623 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0457A

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received : 06/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed : 06/04/2024

NUEVA ECIJA

Date Completed :

06/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)		Thermotolerant Coliform / E. coli	Remarks
		Jampung		(MPN/	(MPN/100mL)	
April Cadena	Villarosa, Licab, N.E.	June 04, 2024 08:02 AM	41	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter
MPN/100mL = Most Probable Number per 100 milliliters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Susana F. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 951-6623 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0457B

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

06/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

06/04/2024

NUEVA ECIJA

Date Completed:

06/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Thermotolerant Coliform / E. coli	Remarks	
		Jumpung	(Est. CFU/mL)	(MPN/	100mL)	
Dindo Dela Cruz	San Cristobal, Licab, N.E.	June 04, 2024 08:18 AM	15	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter MPN/100mL = Most Probable Number per 100 milliliters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Ptale Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Verorica A. Presentacion, RMich Analyst, PAM No. RM 18-00303

Susana F. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 951-6623 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client: LICAB WATER DISTRICT WMAR No: 24-0457C

Owner/Manager: ANNE LORELIE DL, LAURETA Date Received: 06/04/2024

Address REAL ST., POBLACION SUR, LICAB, Date Analyzed: 06/04/2024

NUEVA ECIJA

Date Completed: 06/06/2024

Physical Characteristics: Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count			Thermotolerant Coliform / E. coli	Remarks
	Jampinig	(Est. CFU/mL)		(MPN/	100mL)		
Marciano Cabading	Sta. Maria, Licab, N.E.	June 04, 2024 08:15 AM	2		<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500		<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note: 1. Test method used:

- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli

2. References:

- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Susana F. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 951-6623 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0457D

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received : 06/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

. 00/04/2024

NUEVA ECIJA

Date Analyzed : 06/04/2024

Date Completed:

06/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Thermotolerant Coliform / E. coli	Remarks	
		Jan., pg	(Est. CFU/mL)	(MPN/	100mL)	
Marilyn Pascua	Sta. Maria, Licab, N.E.	June 04, 2024 08:26 AM	<1	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 milliliters

Note .

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMIcro Analyst, PAM No. RM 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

(7) Telephone: (044) 951-6623 local 505

#03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0457E

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received : 06/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

eed: 06/04/2024

NUEVA ECIJA

Date Analyzed :
Date Completed :

06/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of	Heterotrophic Plate Count	Total Coliform		Thermotolerant Coliform / E. coli	Remarks
		Jamping	(Est. CFU/mL)	(MPN/100mL)	100mL)		
Rosalinda Cueco	Pob. Sur, Licab, N.E.	June 04, 2024 08:00 AM	3		<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500		<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note .

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Susana F. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone; (044) 951-6623 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmall.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0457F

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received: 06

06/04/2024

. . .

DEAL OF DODLADION OUR LIGAR

Date Analyzed:

06/04/2024

Address

REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA

Date Completed:

06/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	 al Coliform	Thermotolerant Coliform / E. coli	Remarks
			(Est. CFU/mL)	(MPN/	MPN/100mL)	
Modesta Sarmiento	Pob. Norte, Licab, N.E.	June 04, 2024 08:10 AM	2	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 951-6623 local 505

DOH Accreditation #03-002-2426-LW-1

@ cewdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0457G

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received: 06/04/2024

REAL ST., POBLACION SUR, LICAB,

Address REAL ST., POR NUEVA ECIJA

Date Analyzed : Date Completed : 06/04/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Jumpung		(MPN	/100mL)	
Lorelie Sangil	San Casimiro, Licab, N,E,	June 04, 2024 08:42 AM	<1	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliter MPN/100mL = Most Probable Number per 100 milliters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Susana F. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242