

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-002-2426-LW-1

Telephone: (044) 951-6623 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0200A

Owner/Manager:

ANNE LORELIE DL. LAURETA

03/04/2024

DEAL OF PORLACION CUR LICAR

Date Received : 03/04/20

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed :

03/04/2024

NUEVA ECIJA

Date Completed:

03/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)		Thermotolerant Coliform / E. coli	Remarks
DINDO DELA CRUZ	SAN CRISTOBAL, LICAB, NUEVA ECIJA	March 04, 2024 08:06 AM	2	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Veronica A. Presentación, RMicro Analyst, PAM No. RM 18-00303

Susana F. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines #03-002-2426-LW-1

Telephone: (044) 951-6623 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0200B

Owner/Manager:

ANNE LORELIE DL. LAURETA

03/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed : 03/04/2024

NUEVA ECIJA

Date Completed:

Date Received:

03/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampaniy	(Est. CFU/mL)	(Est. CFU/mL) (MPN/100mL)	100mL)	
LEOVINO CADENA	VILLAROSA. LICAB, NUEVA ECIJA	March 04, 2024 08:22 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Susana . Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District. Cabanatuan City, Philippines

Telephone: (044) 951-6623 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0200C

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

03/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

03/04/2024

NUEVA ECIJA

Date Completed:

03/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		,	(Est. CFU/mL)	(MPN/100mL)	100mL)	
LYN GRACE SANTOS	STA. MARIA, LICAB, NUEVA ECIJA	March 04, 2024 08:05 AM	<1	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 milliliters

Note:

- 1. Test method used:
- n. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

DOH Accreditation #03-002-2426-LW-1

(C) Telephone: (044) 951-6623 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

24-0200D

Owner/Manager:

ANNE LORELIE DL. LAURETA

03/04/2024

REAL ST., POBLACION SUR, LICAB,

Address

Date Analyzed:

WMAR No:

03/04/2024

NUEVA ECIJA

Date Completed:

Date Received:

03/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampung	(Est. CFU/mL)	(MPN/100mL)	100mL)	
FRANCIS GERALD MADRID	STA. MARIA, LICAB, NUEVA ECIJA	March 04, 2024 08:16 AM	<1	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant h Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-002-2426-LW-1

Telephone: (044) 951-6623 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client: LIC

LICAB WATER DISTRICT

24-0200E

Owner/Manager:

ANNE LORELIE DL. LAURETA

03/04/2024

03/04/2024

Address REAL ST., POBLACION SUR, LICAB,

Date Analyzed :

Date Received:

WMAR No:

03/04/2024

NUEVA ECIJA

Date Completed :

03/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Total Coliform Colifo	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		oumpung		(MPN/100mL)		
ROSALINDA CUECO	POBLACION SUR, LICAB, NUEVA ECIJA	March 04, 2024 08:00 AM	53	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 millilters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Veronica A Presentacion, RMicro Analyst, PAM No. RM 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



Date Completed:

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines #03-002-2426-LW-1

24-0200F

03/06/2024

Telephone: (044) 951-6623 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client: LICAB WATER DISTRICT WMAR No :

Owner/Manager: ANNE LORELIE DL. LAURETA Date Received: 03/04/2024

Address REAL ST., POBLACION SUR, LICAB, Date Analyzed: 03/04/2024
NUEVA ECIJA

Physical Characteristics: Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
			(ESC. CFO/IIIE)	(MPN/100mL)	100mL)	
EMILIE AQUINO I	POBLACION NORTE, LICAB, NUEVA ECIJA	March 04, 2024 08:15 AM	7	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note: 7. Test method used:

- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippinės

DOH Accreditation #03-002-2426-LW-1

Telephone: (044) 951-6623 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0200G

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received : 03/04/2024

REAL ST., POBLACION SUR, LICAB,

00/04/2024

Address REAL ST., POI NUEVA ECIJA Date Analyzed:

03/04/2024

Date Completed:

03/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
			(Est. CFU/mL)	(MPN/	/IPN/100mL)	
CORELIE SANGIL	SAN CASIMIRO, LICAB, NUEVA ECIJA	March 04, 2024 08:30 AM	<1	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1 Tost method used
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA.AWWA, WEF
- 3. Result of examination specifically relates to samples as received

erofica A. Presentacion, RMicro Analyst, PAM No. RM 18-00303

Susana . Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242