

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0377A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	05/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	05/06/2024
		Date Completed :	05/08/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Felina Siblag	Sta. Maria, Licab, N.E.	May 06, 2024 07:55 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. RM 18-00303


Susana J. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0377B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	05/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	05/06/2024
		Date Completed :	05/08/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Francis Gerard Madrid	Sta. Maria, Licab, N.E.	May 06, 2024 08:05 AM	4	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quilaolt, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0377D
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	05/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	05/06/2024
		Date Completed :	05/08/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Adelina Cadena	Villarosa, Licab, N.E.	May 06, 2024 08:19 AM	15	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quilaolt, MD, FPSP
Head of the Laboratory, PRC No. 64242

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0377E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	05/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	05/06/2024
		Date Completed :	05/08/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Fortunata Concepcion	San Cristobal, Licab, N.E.	May 06, 2024 08:37 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quilaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0377F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	05/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	05/06/2024
		Date Completed :	05/08/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Brgy. Hall	San Casimiro, Licab, N.E.	May 06, 2024 08:52 AM	2	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E.coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	24-0377G
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	05/06/2024
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	05/06/2024
		Date Completed :	05/08/2024


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Emilie Aquino I	Pob. Norte, Licab, N.E.	May 06, 2024 09:15 AM	8	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quilait, MD, FPSP
Head of the Laboratory, PRC No. 64242