

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-002-2426-LW-1

Telephone: (044) 463-1643 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client: LICAB WATER DISTRICT

WMAR No:

24-0828B

Owner/Manager:

ANNE LORELIE DL. LAURETA

11/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed :

11/04/2024

NUEVA ECIJA

Date Completed:

Date Received:

11/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count		Thermotolerant Coliform / E. coli	Remarks
		Sampung	(Est. CFU/mL)	(MPN/	100mL)	
Adelina Cadena	Villarosa, Licab, N.E.	November 04, 2024 07:38 AM	270	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMIcro Analyst, PAM No. RM 18-00303

Susana F. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District. Cabanatuan City, Philippines

(7) Telephone: (044) 463-1643 local 505

III DOH Accreditation #03-002-2426-LW-1

@ ccwdwalerlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0828C

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

11/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

11/04/2024

NUEVA ECIJA

Date Completed:

11/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sumpung	(Est. CFU/mL)	(MPN/100mL)		
Salome Pallarco	Sta. Maria, Licab, N.E.	November 04, 2024 07:51 AM	38	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-002-2426-LW-1

Telephone: (044) 463-1643 local 505

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0828D

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received: 11/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

11/04/2024

NUEVA ECIJA

Date Analyzed : Date Completed :

11/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	e or Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		22	(Est. CFU/mL)	(MPN/	100mL)	
Lilibeth Enriquez	Sta. Maria, Licab, N.E.	November 04, 2024 08:03 AM	97	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 milliliters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMicro Analyst, PAM No. RM 18-00303

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 463-1643 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0828E

Owner/Manager:

ANNE LORELIE DL. LAURETA

11/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed: 11/04/2024

NUEVA ECIJA

Date Completed:

Date Received:

11/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Jampang	(Est. CFU/mL)	(MPN/	100mL)	
Rosalinda Cueco	Pob. Sur., Licab, N.E.	November 04, 2024 08:08 AM	30	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant b. Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017 a.
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

st, PAM No. RM 18-00303

Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 463 1643 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

Owner/Manager:

ANNE LORELIE DL. LAURETA

Address

REAL ST., POBLACION SUR, LICAB,

NUEVA ECIJA

WMAR No:

24-0828F

Date Received:

11/04/2024

Date Analyzed:

11/04/2024

Date Completed:

11/08/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count		Thermotolerant Coliform / E. coli	Remarks
		Jumpmig	(Est. CFU/mL)	(MPN/	100mL)	
Emilie Aquino I	Pob. Norte, Licab, N.E.	November 04, 2024 08:24 AM	76	<1,1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant b. Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017 a.
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303

Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242

CCWDLAB-FORM02-03

Effective: January 4, 2024



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

Telephone: (044) 463-1643 local 505

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

24-0828G

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

11/04/2024

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

11/04/2024

NUEVA ECIJA

Date Completed:

11/06/2024

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Total Coliform Coliform / E	Thermotolerant Coliform / E. coli	Remarks	
			(Est. CFU/mL)	(MPN/	00mL)	
Lorelie Sangil	San Casimiro, Licab, N.E.	November 04, 2024 08:48 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Veronica A. Presentación, RMicr Analyst, PAM No. RM 18-00303 Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242