

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-002-2426-LW-1

Telephone: (044) 463-1643 local 246

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0127A

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received: 02/05/2025

Address

REAL ST., POBLACION SUR, LICAB,

Date Analyzed : 02/05/2025

NUEVA ECIJA

Date Completed :

02/07/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampung	(Est. CFU/mL)	(MPN/100mL)		
Dindo Dela Cruz	San Cristobal, Licab, N.E.	February 05, 2025 07:51 AM	4	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF

3. Result of examination specifically relates to samples as received

Veronica A. Presentación, RMicro, PFT Analyst, PAM No. RM 18-00303, PRC no. 2215



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-002-2426-LW-1

Telephone: (044) 463-1643 local 246

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No:	25-0127B
Ciletit .	LICAD WATER DISTRICT	WINDAILING.	

Owner/Manager: ANNE LORELIE DL. LAURETA Date Received: 02/05/2025

Address REAL ST., POBLACION SUR, LICAB. Date Analyzed: 02/05/2025

NUEVA ECIJA 02/05/2025

Date Completed: 02/07/2025

Physical Characteristics: Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		Sampling	(Est. CFU/mL)	(MPN/100mL)		
April Tumacder	Villarosa, Licab, N.E.	February 05, 2025 08:11 AM	210	<1.1	<1.1	PASSED
	PNSDW L	imits AO 2017-0010	<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 millilters

Note: 1 Test m

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMicro, PFT Analyst, PAM No. RM 18-00303, PRC no. 2215



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

WATER MICROBIOLOGY ANALYSIS REPORT

DOH Accreditation #03-002-2426-LW-1

@ ccwdwaterlab@gmail.com

Telephone: (044) 463-1643 local 246

Client:

LICAB WATER DISTRICT

WMAR No:

25-0127C

Owner/Manager:

ANNE LORELIE DL. LAURETA

02/05/2025

Address

REAL ST., POBLACION SUR, LICAB,

02/05/2025

NUEVA ECIJA

Date Analyzed :
Date Completed :

Date Received:

02/07/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
	Jamping	(Est. CFU/mL)	(MPN/100mL)			
Lilibeth Enriquez	Sta. Maria, Licab, N.E.	February 05, 2025 08:10 AM	2	<1.1	<1.1	PASSED
	PNSDW Limits AO 2017-0010			<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Veronica A. Presentacion, RMicro, PFT Analyst, PAM No. RM 18-00303, PRC no. 2215

Susana P. Quiaoit, MD, FPSP Head of the Laboratory, PRC No. 64242



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #03-002-2426-LW 1

Telephone: (044) 463-1643 local 246

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0127D

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received : 02/05/2025

Address

REAL ST., POBLACION SUR, LICAB,

NUEVA ECIJA

Date Analyzed :

02/05/2025

Date Completed:

02/07/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / E. coli	Remarks
		~	(EST. CPO/IIIL)	(MPN/100mL)		
Reynaldo R. Madrid, Jr.	Sta. Maria, Licab, N.E.	February 05, 2025 08:25 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant
- Coliform/E.coli
- 2. References: a. Philippine I
- a. Philippine National Standards for Drinking Water, 2017
 - b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303, PRC no. 2215



229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines DOH Accreditation #0.3-002-2426-LW-1

Telephone: (044) 463-1643 local 246

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0127E

Owner/Manager:

ANNE LORELIE DL. LAURETA

02/05/2025

Address

REAL ST., POBLACION SUR, LICAB,

NUEVA ECIJA

Date Analyzed :
Date Completed :

Date Received:

02/05/2025

Physical Characteristics :

Sample is clear, with no foreign matter

Sample Name Address	Date and Time of Sampling	Sampling Plate Count		Thermotolerant Coliform / E. coli	Remarks	
			(Est. CFU/mL)	(MPN/100mL)		
Rosalinda Cueco	Pob. Sur, Licab, N.E.	February 05, 2025 08:30 AM	20	<1,1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- a. Pour Plate Method for the determination of Heterotrophic Plate Count
- b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- a. Philippine National Standards for Drinking Water, 2017
- b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303, PRC no. 2215

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242



er testing laborator[\]

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

DOH Accreditation #03-002-2426-LW-1

(C) Telephone: (044) 463-1643, local 246

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0127F

Owner/Manager:

ANNE LORELIE DL. LAURETA

02/05/2025 Date Received:

REAL ST., POBLACION SUR, LICAB.

Address **NUEVA ECIJA** Date Analyzed:

02/05/2025

Date Completed:

02/07/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name Address	Sampling Plate C	Heterotrophic Plate Count	Total Coliform	Thermotolerant Coliform / E. coli	Remarks	
		(Est. CFU/mL)	(MPN/100mL)			
Emilie Aquino II	Pob. Norte, Licab, N.E.	February 05, 2025 08:40 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303, PRC no. 2215



ER TESTING LABORATOR'

229 Maharlika Road, Dicarma District, Cabanatuan City, Philippines

DOH Accreditation

#03-002-2426-LW-1

(C) Telephone: (044) 463-1643 local 246

@ ccwdwaterlab@gmail.com

WATER MICROBIOLOGY ANALYSIS REPORT

Client:

LICAB WATER DISTRICT

WMAR No:

25-0127G

Owner/Manager:

ANNE LORELIE DL. LAURETA

Date Received:

02/05/2025

REAL ST., POBLACION SUR, LICAB,

Date Analyzed:

02/05/2025

Address **NUEVA ECIJA**

Date Completed:

02/07/2025

Physical Characteristics:

Sample is clear, with no foreign matter

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)		Thermotolerant Coliform / E. coli	Remarks
			(ESC. CI O/IIIE)	(MPN/100mL)		
San Casimiro Pumping Station	San Casimiro, Licab, N.E.	February 05, 2025 09:40 AM	4	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per mililiter

MPN/100mL = Most Probable Number per 100 mililiters

Note:

- 1. Test method used:
- Pour Plate Method for the determination of Heterotrophic Plate Count
- Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant
- b. Coliform/E.coli
- 2. References:
- Philippine National Standards for Drinking Water, 2017
- Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA,AWWA, WEF
- 3. Result of examination specifically relates to samples as received

Analyst, PAM No. RM 18-00303, PRC no. 2215