

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	25-0004A
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/06/2025
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/06/2025
		Date Completed :	01/08/2025


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Zoraida Roque	San Cristobal, Licab, N.E,	January 06, 2025 07:24 AM	3	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303


Susana F. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-04
Effective: January 3, 2025

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 1 of 7

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	25-0004B
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/06/2025
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/06/2025
		Date Completed :	01/08/2025

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Adelina Cadena	Villarosa, Licab, N.E.	January 06, 2025 07:40 AM	4	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMT
Analyst, PAM No. RM 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	25-0004C
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/06/2025
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/06/2025
		Date Completed :	01/08/2025

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Ruth M. Agustin	Sta. Maria, Licab, N.E,	January 06, 2025 07:50 AM	9	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. RM 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-04
Effective: January 3, 2025

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 3 of 7

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	25-0004D
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/06/2025
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/06/2025
		Date Completed :	01/08/2025

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Marilyn Pascua	Sta. Maria, Licab, N.E,	January 06, 2025 08:00 AM	25	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. RM 18-00303


Susana J. Quilaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	25-0004E
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/06/2025
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/06/2025
		Date Completed :	01/08/2025

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Modesta Sarmiento	Pob. Norte, Licab, N.E.	January 06, 2025 08:23 AM	18	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303


Susana F. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-04
Effective: January 3, 2025

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 5 of 7

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	25-0004F
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/06/2025
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/06/2025
		Date Completed :	01/08/2025


Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Rosalinda Cueco	Pob. Sur, Licab, N.E,	January 06, 2025 08:14 AM	8	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. RM 18-00303


Susana J. Quilaolt, MD, FPSP
Head of the Laboratory, PRC No. 64242

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	LICAB WATER DISTRICT	WMAR No :	25-0004G
Owner/Manager :	ANNE LORELIE DL. LAURETA	Date Received :	01/06/2025
Address	REAL ST., POBLACION SUR, LICAB, NUEVA ECIJA	Date Analyzed :	01/06/2025
		Date Completed :	01/08/2025


Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)		
Lorelie Sangil	San Casimiro, Licab, N.E,	January 06, 2025 08:50 AM	7	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E.coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst. PAM No. RM 18-00303


Susana F. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

CCWDLAB-FORM02-04
Effective: January 3, 2025

This report is the confidential property of the client to whom it is addressed. Copying, reproduction, modification and/or distribution of this test report is prohibited unless otherwise authorized.

Page 7 of 7